

MTS

End-of-Life Information

Grundfos MTS pumps must be disposed of according to local regulations by using a public or private waste collection service. If this is not possible, contact the nearest Grundfos company or service workshop.

Safety Risk

Safety related to materials used

- There is no risk for people during the disassembly process posed by the materials used in the product.
- Be sure that the pump is clean and empty for liquid before disassembly.

Safety related to handling the product

- Care should be taken when handling the pump/components due to the weight.

Disassembly of the Product

The main materials of the components are:

- Cast iron
- Stainless steel
- FKM rubber

The MTS pump can therefore be recycled to a large extent – depending on the national possibilities for recycling. To disassemble an MTS pump, standard tools can be used.

Designation	Name	Material	Special Disassembly Consideration
A	Pump cover	Cast iron	
B	Discharge casing	Cast iron	
C	Shaft seal	Stainless steel (1.4571) Seal rings: Silicon carbide / Silicon carbide	
D	Screws	Hardened steel	
E	Rotor housing	Cast iron	
F	Suction casing	Cast iron	
	O-rings	FKM	
Additional materials:		Screws, gaskets etc.: Various materials less than 5% of the weight Screws, gaskets etc.: Various materials less than 5% of the weight	

